



NEYVELI LIGNITE CORPORATION LIMITED

(A Government of India Enterprise)

Office of the Chairman-cum-Managing Director

Regd. Office: 'Neyveli House', No.135, Periyar EVR High Rd., CHENNAI-600 010.

Corporate Office: Block-1, Neyveli-607 801, Cuddalore District, Tamil Nadu.

Phone: 04142/252205. Fax: 04142-252645, 252646

CIN:L93090TN1956GOI003507

WEB-SITE:WWW.NLCINDIA.COM: E-mail:cosec@nlcindia.com

Lr.No.Secy/CI.36/2014

Dt.20.05.2014

To

National Stock Exchange of India Ltd

Plot No.C/1,G Block

Bandra-Kurla Complex

Bandra(E)

MUMBAI-400 051

Scrip Code : NEYVELILIG

Fax No.022-2659 8237/38

Dear sirs,

Sub : Compliance under Clause 36 of the Listing Agreement


We write to inform that an industrial accident occurred today in TPS-I at Neyveli wherein the High Pressure Heater No.8 of Unit-VII (Capacity – 100 MW) got damaged and dislocated, resulting in injuries to six persons including death of one Executive.

The Unit has been shut down immediately and a Committee has been constituted to analyze the cause of the accident and suggest measures to bring back the Unit into operation. The operation of the Unit will be resumed after carrying out the repairs. All other running units of TPS-I are in operation.

This is for your information and record.

Thanking you,

Yours faithfully,
for Neyveli Lignite Corporation Limited


Company Secretary