



NLC INDIA LIMITED

(Navratna - A Government of India Enterprise)

Regd. Office: First Floor, No.8, Mayor Sathyamurthy Road,
FSD, Egmore Complex of Food Corporation of India, Chetpet, Chennai-600 031
Corporate Office: Block-1, Neyveli-607 801, Cuddalore District, Tamil Nadu.
Phone: 04142/252205. Fax: 04142-252645, 252646
CIN: L93090TN1956GOI003507
Web-site: www.nlcindia.com; e-Mail: cosec@nlcindia.in



Lr.No.Secy/Reg. 30 of LODR/2019

Dt.10.06.2019

To
The National Stock Exchange of India Ltd
Plot No. C/1, G Block
Bandra-Kurla Complex
Bandra (E), Mumbai-400 051.
Scrip Code : **NLCINDIA**

Dear sirs,

Sub: Clarification on news item appeared in Business Standard dt. 10.06.2019
Ref: E-mail dt. 10.06.2019

With reference to above cited E-mail dt. 10.06.2019 (received at 16:24 hours) we wish to furnish the following clarifications:

Query a) Whether such event / negotiation/article stated in published news was taking place? If so you are advised to provide the said information along with the sequence of events in chronological order and the material impact of this article on the company.

Reply: Yes. In Thermal Power Station-II (7x210 MW) of NLCIL a fire incident happened on 09-06-2019 A.N in one of the Boilers (Unit-VI, 210 MW) while resuming operation after annual maintenance. This has led to loss of life for one technician and burn injury for another person.

The chronological events are as under.

- On 09.06.2019: At 11:22 AM after over haul, boiler was lighted up for refractory drying with two oil burners in service.
- At 13.24 hrs: There was furnace puffing and smoke emanated from the boiler and the boiler was hand tripped.
- A committee was constituted to make a preliminary assessment of the reasons for the accident and the damages caused and the report was received at 20:00 Hrs on 09.06.2019.

Material impact:

- The company has an installed capacity of 3934.5 MW and the outage unit has the capacity of 210 MW only. This unit of 210 MW is expected to resume its production shortly. Hence, there is no material impact on account of the above incident.

Query b. Whether company are aware of any information that has not announced to the exchanges under regularisation 30 of the SEBI (LODR) regulations, 2015. If so, you are advised to provide the information and the reasons for not disclosing the same to the Exchange earlier required under regulation 30 of the same (LODR) regulations 2015.

Reply: Company is not aware of any information that has not been announced to the exchanges under SEBI regulations.

Thanking you,

Yours faithfully,
for NLC India Limited


Company Secretary

Copy to BSE Ltd.- for information and record

BSE Ltd.

PhirozeJeeJeebhoy Towers

Dalal Street

Mumbai-400 001.

Scrip Code : **513683**